



Any exceeding of these values will result in rejection of the ramp. The Contractor is responsible to ensure that dimensions are within these limits.

MIN

MAX

LOCATION:

INSPECTOR:

DATE:

ROW PERMIT No./PROJECT NAME:

DOMES: Y or N
 DOMES Aligned with Direction of Travel: Y or N
 DOMES > 24" width at all points: Y or N
 DOMES Painted "Brick Red": Y or N
 DOMES Start 6"-8" back of B/C: Y or N
 DOMES full width of bottom of ramp: Y or N

(Any "N" will result in a rejection of the ramp.)

DIMENSIONS OF LEVEL LANDING	
A	5.00'
B	5.00'

GRADE (%)	
1	2.00%
2	2.00%
3	2.00%
4	2.00%
5	2.00%
6	2.00%
7	2.00%
8	2.00%
9	2.00%
10	8.33%
11	8.33%
12	8.33%
13	2.00%
14	2.00%
15	5.00%

CITY OF ANN ARBOR CURB RAMP INSPECTION

