

# ADDENDUM No. 1

ITB No. 4728

## 2023 Utility Infrastructure Materials

**Bids Due: March 23, 2023 at 10:00AM (Local Time)**

The information contained herein shall take precedence over the original documents and all previous addenda (if any) and is appended thereto. **This Addendum includes two (2) pages.**

**Bidder is to acknowledge receipt of this Addendum No. 1, including all attachments (if any) in its Bid by so indicating on page seven (7) of the Invitation to Bid Form. Bids submitted without acknowledgment of receipt of this addendum may be considered nonconforming.**

The following forms provided within the ITB document should be included in submitted bids:

- Vendor Conflict of Interest Disclosure Form
- City of Ann Arbor Non-Discrimination Ordinance Declaration of Compliance

**Bids that fail to provide these forms listed above upon bid opening may be rejected as non-responsive and may not be considered for award.**

### I. QUESTIONS AND ANSWERS

The following Questions have been received by the City. Responses are being provided in accordance with the terms of the ITB. Bidders are directed to take note in their review of the documents of the following questions and City responses as they affect work or details in other areas not specifically referenced here.

Question 1: Can we use the SS1 Repair clamps for Romac?

Answer 1: ROMAC SS1 repair clamps are preferred.

Question 2: Do you also want to use the SS1's with the CC outlets for the Tapping repair clamps?

Answer 2: ROMAC SS1's with CC outlets are preferred.

Question 3: The website states that the Waterous Pacer is approved for the hydrants but the specifications per the 2023 Utility Infrastructure Materials says otherwise. Is the Waterous Pacer allowed?

Answer 3: Yes. Please ensure that the hydrant has the same port configuration and note that it is Waterous Pacer on the line item.

Question 4: We are quoting the ductile fittings and Tyler union quoted import fittings on their end. Do you need domestic or import for these fittings? In the bid docs they said it didn't specify but I wanted to double check with you on this to make sure we quote the right fittings.

Answer 4: Import fittings are acceptable.

Question 5: We just got our quote back from EJ on the valves. Question on that section. Do you want the MJ glands as it has to be quoted w/ acc (glands, cor blue bolts and gaskets) or do you want mega lugs w/ acc quoted?

Answer 5: Individual gate valves shall be provided with accessories packs including standard MJ glands, Cor-Blue bolts and plain rubber gaskets. This is stated at the top of group 5.

Question 6: Also; it says "" AD OP Nut F/4"-12" 500 & 2500 Series Gate Valves" and is it just the op nut price you are looking for?

Answer 6: Yes.

Bidders are responsible for any conclusions that they may draw from the information contained in the Addendum.