

NOVA
ENVIRONMENTAL, INC.
5300 PLYMOUTH ROAD
ANN ARBOR, MICHIGAN 48105
734-930-0995

March 6, 2015

Ms. Jennifer Hall
Executive Director
Ann Arbor Housing Commission
404 N. Ashley
Ann Arbor, MI 48103

RE: Project #CI0168/GC101

Dear Ms. Hall:

Enclosed please find the results of the Radon sampling results collected by us from 2072 Garden Circle, Ann Arbor, Michigan, on January 30, 2015.

The results of these samples analyzed under the action level standards. The US EPA has set an action level for radon of 4 pCi/L. At or above this level of radon, the EPA recommends you re-test before taking corrective measures to reduce your exposure to radon gas.

If you have any questions or if I can be of further assistance, please feel free to contact me at (734) 930-0995.

Sincerely,

NOVA ENVIRONMENTAL, INC.



Jeffrey J. Benya
Senior Environmental Consultant

JJB/ij

Enclosures

Building	Kit Number	Start Date	Start Time	End Date	End Time	Temperature	Room	Result (pCi/L)	Variance	Analysis Date
2072 Garden Circle	4811169	2015-01-30	9:00 am	2015-02-04	12:00 pm	70	Basement	3.4	0.3	2015-02-07
2072 Garden Circle	4811167	2015-01-30	9:00 am	2015-02-04	12:00 pm	70	Living Room	2.5	0.5	2015-02-11

NOVA
ENVIRONMENTAL, INC.
5300 PLYMOUTH ROAD
ANN ARBOR, MICHIGAN 48105
734-930-0995

March 6, 2015

Ms. Jennifer Hall
Executive Director
Ann Arbor Housing Commission
404 N. Ashley
Ann Arbor, MI 48103

RE: Project #CI0168/GC101

Dear Ms. Hall:

Enclosed please find the results of the bulk sample(s) collected by us from 2072 Garden Circle, Ann Arbor, Michigan, throughout, on January 30, 2015. The samples were analyzed utilizing Polarized Light Microscopy (PLM), according to the EPA 600/R-93/116 Method.

If you have any questions or if I can be of further assistance, please feel free to contact me at (734) 930-0995.

Sincerely,

NOVA ENVIRONMENTAL, INC.



Jeffrey J. Benya
Senior Environmental Consultant

JJB/ij

Enclosures



BULK SAMPLING INFORMATION

This form provides information regarding the collection of bulk samples, in accordance with 40 CFR, part 763.85(b)(vii)(B).

1. **Date(s) of Bulk Sampling (Project #CI0168/GC101):**

January 30, 2015

2. **Name of Accredited Inspector(s) who collected Bulk Sample(s):**

Jeffrey J. Benya

3. **Signature of Accredited Inspector(s) who collected Bulk Sample(s):**

A handwritten signature in black ink, appearing to read "Jeffrey J. Benya", is written over a light gray horizontal line.

4. **State of Accreditation of Inspector(s) who collected Bulk Sample(s):**

Michigan

5. **Accreditation Number of Accredited Inspector(s) who collected Bulk Sample(s):**

A15464

Note: Description of the manner used to determine sample locations:

All Samples are collected in accordance with 40 CFR, Part 763.86 and the EPA's Asbestos in Buildings: Simplified Sampling Scheme for Friable Surfacing Materials.

State of Michigan
Department of Licensing and Regulatory Affairs
Michigan Occupational Safety & Health Administration - Asbestos Program

Asbestos Inspector

Jeffrey J. Benya
c/o Nova Environmental, Inc.
5300 Plymouth Road
Ann Arbor, MI 48105



Accreditation Number
A15464

Expiration Date
10/01/2015

DOB: 05/20/1970

This individual has satisfactorily met or exceeded the requirements of Michigan Public Act 440 of 1988, as amended, to be accredited as an Asbestos Inspector.

Accreditation card is not valid if altered.

112142

State of Michigan
Department of Licensing and Regulatory Affairs
Michigan Occupational Safety & Health Administration - Asbestos Program

Asbestos Contractor/Supervisor

Jeffrey J. Benya
c/o Nova Environmental, Inc.
5300 Plymouth Road
Ann Arbor, MI 48105



Accreditation Number
A15464

Expiration Date
10/01/2015

DOB: 05/20/1970

This individual has satisfactorily met or exceeded the requirements of Section 206 of the Toxic Substances Control Act to be accredited in the above discipline.

Accreditation card is not valid if altered.

112143



LABORATORY INFORMATION

1. **Name of Laboratory:**

EMSL

2. **Address of Laboratory:**

212 South Wagner Road, Ann Arbor, MI 48103

3. **Name of Analyst:**

Orlando J. Ivey II

4. **Signature of Analyst:**

See Attached Laboratory Results Sheet

5. **Date(s) of Analysis:**

January 31, 2015

6. **National Voluntary Laboratory Accreditation Program (NVLAP) Number:**

101048-4

7. **Applicable Requirements Statement:**

Samples are analyzed for asbestos by laboratories accredited under the National Voluntary Laboratory Accreditation Program (NVLAP), in accordance with 40 CFR, Part 763.87(a). This program is provided under the auspices of the United States Department of Commerce National Institute of Standards and Technology. Question #6 provides the NVLAP Accreditation Number for the laboratory, which performed the asbestos bulk analysis on the samples.

2072 Garden Circle

Bulk Sample Collection Sheet

ACM Sample #	Homogeneous Area Description	F/NF	S/TSI/M	Sample Location	Asbestos Result
CI0110/GC101-001A	12" x 12" Floor Tile - Orange	NF	M	Kitchen/Dining Room	None Detected
CI0110/GC101-001B	Mastic for 12" x 12" Floor Tile - Orange	NF	M	Kitchen/Dining Room	None Detected
CI0110/GC101-002A	12" x 12" Floor Tile - Green	NF	M	Living Room	None Detected
CI0110/GC101-002B	Mastic for 12" x 12" Floor Tile - Green	NF	M	Living Room	None Detected
CI0110/GC101-003A	12" x 12" Floor Tile - Blue	NF	M	Bathroom	None Detected
CI0110/GC101-003B	Mastic for 12" x 12" Floor Tile - Blue	NF	M	Bathroom	None Detected
CI0110/GC101-004A	12" x 12" Floor Tile - Blue Mottled	NF	M	Master Bedroom	None Detected
CI0110/GC101-004B	Mastic for 12" x 12" Floor Tile - Blue Mottled	NF	M	Master Bedroom	None Detected
CI0110/GC101-005A	9" x 9" Floor Tile - Brown	NF	M	Back Bedroom	None Detected
CI0110/GC101-005B	Mastic for 9" x 9" Floor Tile - Brown	NF	M	Back Bedroom	None Detected
CI0110/GC101-006	Drywall Wall	NF	M	Living Room	None Detected
CI0110/GC101-007	Drywall Ceiling	NF	M	Living Room	None Detected
CI0110/GC101-008	Window Caulk - White	NF	M	Back Bedroom	None Detected
CI0110/GC101-009	Sink Undercoating - White	NF	M	Kitchen	None Detected
CI0110/GC101-010	Concrete Wall	NF	M	Basement	None Detected
CI0110/GC101-011	Concrete Floor	NF	M	Basement	None Detected
CI0110/GC101-012A	12" x 12" Floor Tile - Mauve	NF	M	Front Bedroom	None Detected
CI0110/GC101-012B	Mastic for 12" x 12" Floor Tile - Mauve	NF	M	Front Bedroom	None Detected
CI0110/GC101-013	Attic Vapor Barrier	NF	M	Attic	None Detected
CI0110/GC101-014	Exterior Brick	NF	M	Front of Building	None Detected
CI0110/GC101-015	Exterior Brick Mortar	NF	M	Front of Building	None Detected
CI0110/GC101-016	Exterior Door Caulk - White	NF	M	Front of Building	None Detected
CI0110/GC101-017	Exterior Window Caulk - White	NF	M	Front of Building	None Detected

**EMSL Analytical, Inc.**

212 South Wagner Road, Ann Arbor, MI 48103

Phone/Fax: (734) 668-6810 / (734) 668-8532

<http://www.EMSL.com>annarborlab@emsl.com

EMSL Order:	081500158
CustomerID:	NOVA53
CustomerPO:	
ProjectID:	


Attn: **Jeff Benya**
Nova Environmental, Inc
5300 Plymouth Rd
Ann Arbor, MI 48105


Phone: (734) 930-0995
 Fax: (734) 930-2969
 Received: 01/30/15 11:00 AM
 Analysis Date: 1/31/2015
 Collected:

Project: **CI0168/GC101**

Test Report: Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 Method using Polarized Light Microscopy

Sample	Description	Appearance	Non-Asbestos		Asbestos
			% Fibrous	% Non-Fibrous	% Type
CI0168/GC101-001A 081500158-0001	Floor tile	Pink Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected
CI0168/GC101-001B 081500158-0002	Mastic	Brown Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected
CI0168/GC101-002A 081500158-0003	Floor Tile	Green Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected
CI0168/GC101-002B 081500158-0004	Mastic	Brown Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected
CI0168/GC101-003A 081500158-0005	Floor Tile	Blue Fibrous Homogeneous	<1% Cellulose	100% Non-fibrous (other)	None Detected
CI0168/GC101-003B 081500158-0006	Mastic	Brown/Tan Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected
CI0168/GC101-004A 081500158-0007	Floor Tile	Gray/Blue Fibrous Homogeneous		100% Non-fibrous (other)	None Detected

Analyst(s) 
 Orlando J. Ivey II (24)


 Ryan Shannon, Laboratory Manager
 or other approved signatory

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. This report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST or any agency of the federal government. Non-friable organically bound materials present a problem matrix and therefore EMSL recommends gravimetric reduction prior to analysis. Samples received in good condition unless otherwise noted. Estimated accuracy, precision and uncertainty data available upon request. Unless requested by the client, building materials manufactured with multiple layers (i.e. linoleum, wallboard, etc.) are reported as a single sample. Reporting limit is 1%
 Samples analyzed by EMSL Analytical, Inc. Ann Arbor, MI NVLAP Lab Code 101048-4

Initial report from 02/02/2015 09:58:06

**EMSL Analytical, Inc.**

212 South Wagner Road, Ann Arbor, MI 48103
 Phone/Fax: (734) 668-6810 / (734) 668-8532
<http://www.EMSL.com> annarborlab@emsl.com

EMSL Order: 081500158
 CustomerID: NOVA53
 CustomerPO:
 ProjectID:


Attn: **Jeff Benya**
Nova Environmental, Inc
5300 Plymouth Rd
Ann Arbor, MI 48105


Phone: (734) 930-0995
 Fax: (734) 930-2969
 Received: 01/30/15 11:00 AM
 Analysis Date: 1/31/2015
 Collected:

Project: **CI0168/GC101**

Test Report: Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 Method using Polarized Light Microscopy

Sample	Description	Appearance	Non-Asbestos		Asbestos
			% Fibrous	% Non-Fibrous	% Type
CI0168/GC101-004B <i>081500158-0008</i>	Mastic	Brown Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected
CI0168/GC101-005A <i>081500158-0009</i>	Floor Tile	Black Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected
CI0168/GC101-005B <i>081500158-0010</i>	Mastic	Clear Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected
CI0168/GC101-006 <i>081500158-0011</i>		Gray Fibrous Homogeneous	15% Cellulose	85% Non-fibrous (other)	None Detected
CI0168/GC101-007A <i>081500158-0012</i>	Joint Compound	White Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected
CI0168/GC101-007B <i>081500158-0012A</i>	Drywall	White Fibrous Homogeneous	20% Cellulose	80% Non-fibrous (other)	None Detected
CI0168/GC101-008 <i>081500158-0013</i>		Gray Non-Fibrous Homogeneous	2% Cellulose	98% Non-fibrous (other)	None Detected
CI0168/GC101-009 <i>081500158-0014</i>		Gray Fibrous Homogeneous	6% Cellulose	94% Non-fibrous (other)	None Detected

Analyst(s) 
 Orlando J. Ivey II (24)


 Ryan Shannon, Laboratory Manager
 or other approved signatory

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. This report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST or any agency of the federal government. Non-friable organically bound materials present a problem matrix and therefore EMSL recommends gravimetric reduction prior to analysis. Samples received in good condition unless otherwise noted. Estimated accuracy, precision and uncertainty data available upon request. Unless requested by the client, building materials manufactured with multiple layers (i.e. linoleum, wallboard, etc.) are reported as a single sample. Reporting limit is 1%
 Samples analyzed by EMSL Analytical, Inc. Ann Arbor, MI NVLAP Lab Code 101048-4

Initial report from 02/02/2015 09:58:06

**EMSL Analytical, Inc.**

212 South Wagner Road, Ann Arbor, MI 48103

Phone/Fax: (734) 668-6810 / (734) 668-8532

<http://www.EMSL.com>annarborlab@emsl.com

EMSL Order: 081500158

CustomerID: NOVA53

CustomerPO:

ProjectID:

Attn: **Jeff Benya**
Nova Environmental, Inc
5300 Plymouth Rd
Ann Arbor, MI 48105

Phone: (734) 930-0995
 Fax: (734) 930-2969
 Received: 01/30/15 11:00 AM
 Analysis Date: 1/31/2015
 Collected:

Project: **CI0168/GC101**

Test Report: Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 Method using Polarized Light Microscopy

Sample	Description	Appearance	Non-Asbestos		Asbestos
			% Fibrous	% Non-Fibrous	% Type
CI0168/GC101-010 081500158-0015		Gray Fibrous Homogeneous	<1% Cellulose	100% Non-fibrous (other)	None Detected
CI0168/GC101-011 081500158-0016		Gray Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected
CI0168/GC101-012A 081500158-0017		Gray/Pink Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected
CI0168/GC101-012B 081500158-0018		Brown Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected
CI0168/GC101-013 081500158-0019		Brown/Gray Fibrous Homogeneous	6% Glass	94% Non-fibrous (other)	None Detected
CI0168/GC101-014 081500158-0020		Red/Pink Fibrous Homogeneous	2% Glass	98% Non-fibrous (other)	None Detected
CI0168/GC101-015 081500158-0021		Gray Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected
CI0168/GC101-016 081500158-0022		Gray/W white Fibrous Homogeneous	2% Cellulose 3% Glass	95% Non-fibrous (other)	None Detected

Analyst(s)

Orlando J. Ivey II (24)

Ryan Shannon, Laboratory Manager
or other approved signatory

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. This report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST or any agency of the federal government. Non-friable organically bound materials present a problem matrix and therefore EMSL recommends gravimetric reduction prior to analysis. Samples received in good condition unless otherwise noted. Estimated accuracy, precision and uncertainty data available upon request. Unless requested by the client, building materials manufactured with multiple layers (i.e. linoleum, wallboard, etc.) are reported as a single sample. Reporting limit is 1%

Samples analyzed by EMSL Analytical, Inc. Ann Arbor, MI NVLAP Lab Code 101048-4

Initial report from 02/02/2015 09:58:06

**EMSL Analytical, Inc.**

212 South Wagner Road, Ann Arbor, MI 48103

Phone/Fax: (734) 668-6810 / (734) 668-8532

<http://www.EMSL.com>annarborlab@emsl.com

EMSL Order: 081500158

CustomerID: NOVA53

CustomerPO:

ProjectID:

Attn: **Jeff Benya**
Nova Environmental, Inc
5300 Plymouth Rd
Ann Arbor, MI 48105

Phone: (734) 930-0995
 Fax: (734) 930-2969
 Received: 01/30/15 11:00 AM
 Analysis Date: 1/31/2015
 Collected:

Project: CI0168/GC101

Test Report: Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 Method using Polarized Light Microscopy

Sample	Description	Appearance	Non-Asbestos		Asbestos
			% Fibrous	% Non-Fibrous	% Type
CI0168/GC101-017		Gray/White		100% Non-fibrous (other)	None Detected
081500158-0023		Non-Fibrous Homogeneous			

Analyst(s)

Orlando J. Ivey II (24)

Ryan Shannon, Laboratory Manager
or other approved signatory

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. This report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST or any agency of the federal government. Non-friable organically bound materials present a problem matrix and therefore EMSL recommends gravimetric reduction prior to analysis. Samples received in good condition unless otherwise noted. Estimated accuracy, precision and uncertainty data available upon request. Unless requested by the client, building materials manufactured with multiple layers (i.e. linoleum, wallboard, etc.) are reported as a single sample. Reporting limit is 1%
 Samples analyzed by EMSL Analytical, Inc. Ann Arbor, MI NVLAP Lab Code 101048-4

Initial report from 02/02/2015 09:58:06