



Environmental Resources Group

28003 Center Oaks Court • Suite 106 • Wixom, MI • 48393
Phone: 248-773-7986 • Fax: 248-924-3108

August 8, 2013

Mr. Richard Higgins
Norstar Development USA, L.P.
733 Broadway
Albany, New York 12207

**Re: Asbestos Containing Material Survey
Maple Meadows
800-890 S. Maple, Ann Arbor, Michigan
ERG Project 1129.002**

Dear Mr. Higgins,

Environmental Resources Group, LLC (ERG) has completed the pre-renovation asbestos containing material survey (ACM Survey) for the referenced property in Ann Arbor, Michigan.

ERG contracted American Environmental Consultants (AEC) to perform the survey. The asbestos survey was performed on May 30 and June 3, 2013 by an accredited Asbestos Inspector in general accordance with NESHAP Guidelines, with the focus on satisfying the regulatory ACM information requirements for building renovation activities. The pre-renovation ACM survey targeted readily accessible building materials and included the collection and analysis of bulk samples. Samples were analyzed by the polarized light microscopy (PLM) and/or Point Count methods.

The results of the pre-renovation ACM survey indicated that two materials (joint compound and heat shield) were found to contain asbestos and are deemed ACMs. In addition, two materials (lower layers of floor tile and roofing material) were not sampled and are therefore assumed to be ACMs.

Please refer to the attached AEC report for survey details and analytical results.

Thank you for the opportunity to provide this service to you. If you have any questions, please contact us at 248-773-7986.

Sincerely,
ENVIRONMENTAL RESOURCES GROUP, LLC

Andrew J. Foerg, CPG
Senior Project Manager

Enclosures