

WATER FLOW TEST REPORT

HYDRANT # LOCATION: **02-00047 106 Packard** DATE: **5/13/2022**

TEST BY: **Arbor Inspection/AAFL** Day or Week: **Friday** TIME OF DAY: **10:30** MIN. OF FLOW: **5**

WATER SUPPLIED BY: **Municipal**

PURPOSE OF TEST: **REQUEST BY: Arbor iNspction Services**

DATA

FLOW HYDRANT(S)	02-00067	02-00067	02-00067
SIZE OPENING:	2.5	2.5	
COEFFICIENT:	0.9	0.9	
PITOT READING:	24	20	
GPM:	822	750	0

TOTAL FLOW DURING TEST: **1572** GPM

STATIC READING: **65** PSI

RESIDUAL: **60** PSI

RESULTS: AT 20 PSI RESIDUAL **5151** GPM

AT 0 PSI **6282** GPM

ESTIMATED CONSUMPTION: **7862** GAL.

REMARKS:

