

ADDENDUM No. 1

ITB No. 4571

WTP AMMONIA FEED SYSTEM MODIFICATIONS

Bids Due: March 8, 2019 at 2:00 P.M. (Local Time)

The following changes, additions, and/or deletions shall be made to the Invitation to Bid for WTP Ammonia Feed System Modifications, ITB No. 4571, on which proposals will be received on/or before Friday, March 8, 2019., at 2:00 P.M. (local time).

The information contained herein shall take precedence over the original documents and all previous addenda (if any), and is appended thereto. **This Addendum includes four (4) pages.**

Bidder is to acknowledge receipt of this Addendum No. 1, including all attachments (if any) in its Bid by so indicating on page ITB-1 of the Invitation to Bid Form. Bids submitted without acknowledgment of receipt of this addendum will be considered nonconforming.

The following forms provided within the ITB document must be included in submitted bids:

- City of Ann Arbor Prevailing Wage Declaration of Compliance
- City of Ann Arbor Living Wage Ordinance Declaration of Compliance
- Vendor Conflict of Interest Disclosure Form
- City of Ann Arbor Non-Discrimination Ordinance Declaration of Compliance

Bids that fail to provide these completed forms listed above upon bid opening will be rejected as non-responsive and will not be considered for award.

I. CORRECTIONS/ADDITIONS/DELETIONS

Changes to the Bid document which are outlined below are referenced to a page or Section in which they appear conspicuously. The Bidder is to take note in its review of the documents and include these changes as they may affect work or details in other areas not specifically referenced here. Changes to the original text are in bold and italics.

<u>Section/Page(s)</u>	<u>Change</u>
Bid Form, BF-1	Replace with attached.
40 05 13 – 3	Add the following paragraph 2.1.E: <i>E. Braided Stainless Steel Hose:</i> <i>1. Use: Flexible connection to/from Day Tank to account for slight movement of tank on scale.</i> <i>2. Hose: Extreme-Temperature Air and Steam Hose</i> <i>3. Material: Type 316 stainless steel</i> <i>4. Chemical capability: Compatible with anhydrous ammonia</i> <i>5. Size: 1-1/4" or as indicated on Drawings, or to match connections.</i> <i>6. Fittings: NPT Male threaded connections</i> <i>7. Manufacturer: McMaster-Carr; or equal.</i>

II. QUESTIONS AND ANSWERS

Q: Is the electrical work to be included in our price?

A: Yes, include all costs related to electrical and controls in Revised Bid Form Item No. 4.

Pre-bid sign in sheet is attached.

Respondents are responsible for any conclusions that they may draw from the information contained in the Addendum.

BID FORM

Section 1 – Schedule of Prices

Company: _____

Project: **Water Treatment Plant Ammonia Feed System Modifications - ITB No. 4571**

Notes:

1. All bidders shall provide a Unit Price and Total Price for all bid items specified.
2. The City, at its sole discretion, may elect to delete any portion of the work delineated below, with no change to the unit prices provided. Work shall be determined based upon the availability of funds.
3. Any item not provided in the following list shall be considered incidental.
4. Contract shall be awarded based on the base bid or any combination of base bid and alternate bid in any manner the City believed to be in its best interest.

Bid Items

The Bidder agrees to complete the Project and all related work, as specified and shown on the drawings, for the following unit prices.

AMMONIA FEED SYSTEM MODIFICATIONS – ITB 4571 BASE BID					
Item No.	Item Description	Qty	Unit	Unit Price	Total Price
1.	General Conditions (Max, 10% of total bid)	1	LS	\$	\$
2.	Ammonia Piping and Tank Modifications	1	LS	\$	\$
3.	Ammonia Feed Equipment (using Hydro Instruments)	1	LS	\$	\$
4.	<i>Electrical, Instrumentation and Controls</i>	1	LS	\$	\$
5.	Start-Up, Commissioning, and Training	1	LS	\$	\$
6.	Final Closeout	1	LS	\$	\$
7.	Temporary Ammonia Feed System Allowance	1	ALW	\$30,000	\$30,000
8.	Permit Allowance	1	ALW	\$ 5,000	\$ 5,000
9.	Miscellaneous Allowance	1	ALW	\$10,000	\$10,000
10.	Certified Payroll Compliance and Reporting	1	LS		
TOTAL BASE BID (ITEMS 1 THROUGH 10)					\$

Total Base Bid: _____ Dollars
(\$ _____)

(Amount shall be shown in both words and figures. In case of a discrepancy, the amount shown in words shall govern.)



CITY OF ANN ARBOR
WATER TREATMENT SERVICES

Sign-in Sheet

Water Treatment Plant Ammonia Feed System Modifications

Pre-Bid Meeting

ITB# 4571

Date: Thursday, February 14, 2019 @ 2:00 p.m.

List of Attendees:

Name (Please Print)	Company	Email Address/Phone Number
1. Mario Fernandez	Sherwin-Williams	313 316 1475 Mario.E.Fernandez@sherwin.com
2. RAY STOVES III	SHERWIN WILLIAMS	SW1764@SHERWIN.COM 734-677-5564
3. Joe Calhoun	Mid American Group	734 586 8868 jcalhoun@midamericagroup.com
4. Mike Binder	Erie Welding	mbinder@erieweldingand mechanical.com 734-848-8361
5. Emily Schlanderer	FTCH AA WTP	eschlanderer@a2gov.org (734) 794-6426
6.		
7.		
8.		

