

Sample Month - Year	Concentration of 1,4-Dioxane (ppb)		
	Huron River at Barton Pond	Groundwater Wells at Steere Farm	City of Ann Arbor Drinking Water
Jan-18	ND	ND	ND
Feb-18	ND	ND	ND
Mar-18	ND	0.083	ND
Apr-18	ND	ND	ND
May-18	ND	ND	ND
Jun-18	ND	ND	ND
Jul-18	ND	ND	ND
Aug-18	ND	ND	ND
Sep-18	Lab Error	ND	ND
Oct-18	ND	ND	ND
Nov-18	ND	ND	ND
Dec-18	0.067 J	ND	ND
Jan-19	ND	ND	ND
Feb-19	0.061 J	ND	0.030 J
Mar-19, lab 1	ND	ND	ND
Mar-19, duplicate, lab 1	ND	--	ND
Mar-19, lab 2	ND	--	ND

Abbreviations

ppb = parts per billion, equivalent to micrograms per liter

ND = not detected

J = estimated concentration above the adjusted method detection limit and below the adjusted reporting limit

-- = not sampled

Notes

1. In September 2018, the independent contract lab made an error and no result is available for the Huron River at Barton Pond.

2. Environmental Protection Agency (EPA) risk assessments indicate that the drinking water concentration above which represents a 1 in 1,000,000 risk of cancer based on a lifetime of consumption, is 0.35 parts per billion. Current detectable levels in the city's drinking water is not considered to be a health risk.

3. Currently 1,4-dioxane is not regulated in drinking water at the federal level or in Michigan. Several states have implemented regulations for this chemical at levels between 0.3 parts per billion and 77 parts per billion. The city's drinking water levels remain 10 times lower than the most stringent regulation that exists in the United States.