

# ADDENDUM No. 1

ITB No. 4784

## Water Treatment Chemical - Carbon Dioxide (CO<sub>2</sub>)

**Bids Due: April 14, 2026 at 11:00 A.M. (Local Time)**

The information contained herein shall take precedence over the original documents and all previous addenda (if any) and is appended thereto. **This Addendum includes 1 page.**

**Bidder is to acknowledge receipt of this Addendum No. 1, including all attachments (if any) in its Bid by so indicating on page 8 of the Invitation to Bid. Bids submitted without acknowledgment of receipt of this addendum may be considered nonconforming.**

The following forms provided within the ITB document should be included in submitted bids:

- Vendor Conflict of Interest Disclosure Form
- City of Ann Arbor Non-Discrimination Ordinance Declaration of Compliance

**Bids that fail to provide these forms listed above upon bid opening may be rejected as non-responsive and may not be considered for award.**

## I. QUESTIONS AND ANSWERS

The following Questions have been received by the City. Responses are being provided in accordance with the terms of the ITB. Bidders are directed to take note in their review of the documents of the following questions and City responses as they affect work or details in other areas not specifically referenced here.

Question 1: Can you confirm the average flow-rates of CO<sub>2</sub>?

Answer 1: CO<sub>2</sub> average usage rate over the past year was 120 lb/hr.

Question 2: Are there any peaks in the flowrates (specific times of day, seasonal, etc.)? If peaks exist, can you confirm that average flow and it's average duration?

Answer 2: CO<sub>2</sub> flowrate fluctuates throughout the day and seasonally. It is highest in winter and spring months and lowest in fall. Over the past year, average in winter was 160 lb/hr and 70 lb/hr in fall.

Bidders are responsible for any conclusions that they may draw from the information contained in the Addendum.