

ADDENDUM 1

October 17, 2025

IFB #AAHC-25-4

RESPONSE TO RFI

Question: Is it acceptable to run the SER cables through the basements of the units rather than under the patios as shown in the IMEG drawings?

Answer: Yes, this is an acceptable alternative to the drawing in the IFB.