

ADDENDUM No. 1

RFP# 26-28 - Primary and Secondary Clarifiers Inspection & Repair

Due: May 5, 2026 at 11:00 A.M. (local time)

The information contained herein shall take precedence over the original documents and all previous addenda (if any), and is appended thereto. **This Addendum includes two (2) pages.**

The Proposer is to acknowledge receipt of this Addendum No. 1 by signing and submitting Attachment B, including all attachments in its Proposal by so indicating in the proposal that the addendum has been received. Proposals submitted without acknowledgement of receipt of this addendum may be considered non-conforming.

The following forms provided within the RFP Document should be included in submitted proposal:

- **Attachment B - General Declarations**
- **Attachment D - Prevailing Wage Declaration of Compliance**
- **Attachment E - Living Wage Declaration of Compliance**
- **Attachment G - Vendor Conflict of Interest Disclosure Form**
- **Attachment H - Non-Discrimination Declaration of Compliance**

Proposals that fail to provide these completed forms listed above upon proposal opening may be rejected as non-responsive and may not be considered for award.

I. QUESTIONS AND ANSWERS

The following Questions have been received by the City. Responses are being provided in accordance with the terms of the RFP. Respondents are directed to take note in its review of the documents of the following questions and City responses as they affect work or details in other areas not specifically referenced here.

Question 1: Does the city have contacts for Ovivo?

Answer 1: Yes. Local representative is Waterworks Systems & Equipment, Chuck Kronk
Email: Ckronk@waterworkssystem.com. Ovivo Technician Douglas King Email:
Doug.King@ovivowater.com.

Question 2: Should the Contractors submit bids in a lump sum or per clarifier.

Answer 2: The City is seeking one base bid amount for the entire project as outlined on Page 16 of the RFP Document.

Question 3: What is the shutdown procedure including a timeline at the WRRF?

Answer 3: For this project, we will ensure that the tanks are prepared prior to the start of work. If a shutdown is required, a written request must be submitted to plant staff at least 10 days before the desired shutdown date. Approval would be determined based on weather conditions, plant operations and staffing. The Contractor will be given approval approximately 72 hours prior to shutdown.

Question 4: What is the expected completion timeframe for the project?

Answer 4: The project is expected to be completed within 120 calendar days from signed and executed contract.

Question 5: There are many qualified people in the industry that can evaluate clarifier repairs and, in my opinion, it doesn't need to be an Ovivo guy. Can Sentry Equipment Corp / Rebuild-It be approved As Equal to perform the required inspection?

Answer 5: A qualified contractor may perform the necessary repair work. The City is requesting that the Contractor coordinate and fund one (1) full-day visit from an authorized Ovivo Field Service Representative. The Field Service Representative shall perform a final installation inspection and verify the rake arm leveling before the Contractor performs any final welding.

Offerors are responsible for any conclusions that they may draw from the information contained in the Addendum.