



**CITY OF ANN ARBOR, MICHIGAN**

301 E. Huron Street, Ann Arbor, Michigan 48104

Phone (734) 794-6350

Website: [www.a2gov.org](http://www.a2gov.org)

Parks and Recreation Services

April 18, 2014

To: All Contract Document Holders

**RE: Addendum to the Contract Documents for the Buhr Park and Fuller Park Pool Surface Improvements  
Bid No. ITB-4326**

Attached is a copy of Addendum Number Two for the Buhr Park and Fuller Park Pool Surface Improvements Project. This Addendum supersedes and updates the Contract Document information for Bid No. ITB-4326. All Bidders shall acknowledge receipt and acceptance of this Addendum Number Two by so indicating on the Invitation to Bid Form located in the existing Contract Documents. Bids submitted without acknowledgment of receipt of this Addendum will be considered informal. If you have any questions regarding the Contract Documents or this Addendum, please contact Glen Wiczorek, PE, Stantec Consulting, Project Manager by email at [glen.wiczorek@stantec.com](mailto:glen.wiczorek@stantec.com).

If you have any questions about the content of this letter, please feel free to contact me at (734) 794-6230 x42590.

Sincerely,  
CITY OF ANN ARBOR  
Amy Kuras  
Project Manager, Parks and Recreation

cc: Glen Wiczorek, Stantec

April 18, 2014

**ADDENDUM NO. 2  
TO  
BID DOCUMENTS  
FOR  
BUHR PARK AND FULLER PARK POOL  
SURFACE IMPROVEMENTS  
FOR THE  
CITY OF ANN ARBOR, MICHIGAN**

The following changes, additions, and/or deletions shall be made to the Bid Documents for the Buhr Park and Fuller Park Pool Surface Improvements Project for the City of Ann Arbor, Michigan, Bid No. ITB – 4326 on which bids are to be received, on or before, 2:00 P.M. Tuesday, April 24, 2014.

The information contained herein shall take precedence over the original documents and all previous addenda, and is appended thereto.

**All Bidders shall acknowledge receipt and acceptance of this Addendum No. 2, including all attachments, by so indicating on page ITB-1 of the Invitation to Bid Form. Bids submitted without acknowledgement of receipt of this addendum will be considered informal.**

Changes in the Bid Documents which are outlined below are referenced to a page or drawing in which they appear conspicuously. The Bidder is to take note in its review of the documents and include these changes as they affect work or details in other areas not specifically referenced here. Changes to the original text are bolded, underlined and italicized.

**TECHNICAL SPECIFICATIONS**

**Add** Section 2.3 Paragraph M to Specification 13150 Adhered PVC Swimming Pool Lining System as follows:

**2.3 SYSTEM COMPONENTS**

- M. A 6-inch gutter skirt shall be installed around the perimeter of all pools to permit attachment of the PVC pool membrane. The gutter skirt shall be 12 gauge 304 stainless steel. The gutter skirt shall be continuously welded to the existing stainless steel gutter system. Stainless steel drive anchors shall also be installed every 12” into the existing pool concrete.

## QUESTIONS AND ANSWERS

Q: How far shall the non-skid/textured surface liner be extended at Fuller Park?

A: **The non-skid/textured surface liner shall be extended to cover the complete shallow leg of the Fuller Pool, up to the point where the lap lanes begin.**

Q: Is 100% of the existing marcite (plaster) required to be removed over the entirety of the pools?

A: **Yes, the existing marcite (plaster) must be fully removed down to sound concrete.**

**END OF ADDENDUM**