

Asbestos Containing Materials by Property – updated April 2023

Building	Identified or Presumed Asbestos Containing Building Material
Baker Commons	Sink undercoating
Broadway	Presumed in roofing material
Garden	None
Green Baxter	Drywall Systems, heat shield, floor tile and presumed roofing materials. None in building 1725-1735 newly constructed in 2015
Hikone	Drywall Systems, heat shield, floor tile/underlayment and presumed roofing materials
Hillside Manor	None – Roof replaced in 2015
Creekside Court on Platt Road	None – new construction 2020
Lurie Terrace 600 W Huron	Joint compound basement maintenance shop, common area stairs, and apartments, popcorn ceilings only. Presumed but not tested in vinyl flooring and cove base materials and associated mastics, carpet mastics, ceramic tile and grout, cinder block and mortar, brick and mortar, caulking/firestop materials, and roofing materials.
Mallets Creek	None – Roof replaced in 2015
Maple Meadows	Drywall Systems, heat shield, floor tile and presumed roofing materials
Miller Manor	Drywall Systems tower portion of building only, floor tile/mastic (removed in 2013), sink undercoating, exterior cement caulk, ceiling tile (removed in 2015) and presumed roofing materials
Oakwood	Drywall Systems in 3565 and 3575 only, roof replaced in 2014
Seventh	None – roof replaced in 2016
Upper Platt 3681 -3689 Platt	Roof replaced in 2016, presumed cloth duct isolation joints in basements
West Arbor on North Maple	None, New Construction 2016, 3-bdr duplexes cleared
W. Washington	None – roof replaced in 2015
State Crossing	None – new construction 2020
Siller Terrace 1474 – 1484 Liberty 1540 – 1582 Siller 528 Virginia	Liberty: Floor tiles - yes. The bathtub undercoating and roof are presumed Siller: Floor tiles and vent caulk - yes. The vibration dampener, bathtub undercoating & surround adhesive, and roofing materials are presumed Virginia: Floor tiles – yes. Roof presumed
Industrial	Floor tile, exterior window caulk and glaze, vermiculite insulation, presumed in electrical wire insulation

TEST RESULTS are posted at www.a2gov.org/housingcommission