

ADDENDUM No. 2

ITB No. 4550

WTP Ozone Generation Building Chiller Replacement

Bids Due: Monday, September 24, 2018 at 2:00 P.M. (Local Time)

The following changes, additions, and/or deletions shall be made to the Invitation to Bid for WTP Ozone Generation Building Chiller Replacement, ITB No. 4550, on which proposals will be received on/or before Monday, September 24, 2018, at 2:00 P.M. (local time).

The information contained herein shall take precedence over the original documents and all previous addenda (if any) and is appended thereto. **This Addendum includes six (6) pages.**

Bidder is to acknowledge receipt of this Addendum No. 2, including all attachments (if any) in its Bid by so indicating on page ITB-1 of the Invitation to Bid Form. Bids submitted without acknowledgment of receipt of this addendum will be considered nonconforming.

The following forms provided within the ITB document must be included in submitted bids:

- City of Ann Arbor Prevailing Wage Declaration of Compliance
- City of Ann Arbor Living Wage Ordinance Declaration of Compliance
- Vendor Conflict of Interest Disclosure Form
- City of Ann Arbor Non-Discrimination Ordinance Declaration of Compliance

Bids that fail to provide these completed forms listed above upon bid opening will be rejected as non-responsive and will not be considered for award.

I. CORRECTIONS/ADDITIONS/DELETIONS

Changes to the Bid document which are outlined below are referenced to a page or Section in which they appear conspicuously. The Bidder is to take note in its review of the documents and include these changes as they may affect work or details in other areas not specifically referenced here.

<u>Section/Page(s)</u>	<u>Change</u>
Drawing E-102	Updates and corrects to drawing notes.

II. QUESTIONS AND ANSWERS

The following Questions have been received by the City. Responses are being provided in accordance with the terms of the RFP. Offerors are directed to take note in their review of the documents of the following questions and City responses as they affect work or details in other areas not specifically referenced here.

Question 1: Could you please clarify how many Variable Speed Drives are to be provide in the Contract.



Answer 1: Two (2) 30 Horsepower Driver are to be provided. There are for the horizontal split case pumps for cooling water recirculation pumps.

Question 2: Can an Attendance List of the Pre-Bid meeting be provided.

Answer 2: See Attachment.

Respondents are responsible for any conclusions that they may draw from the information contained in the Addendum.

REVISION	By	Appd	YYYY.MM.DD	
ADDENDUM	GS	WA	2018.09.20	
ADDENDUM	GS	WA	2018.09.19	
A FINAL CLIENT REVIEW	GS	WA	2018.08.07	
Issued	By	Appd	YYYY.MM.DD	
File Name: 2075139804_E-102	GK	GS	JW	2018.08.07
	Dwn.	Dgrn.	Chkd.	YYYY.MM.DD



GROUND FLOOR PLAN
3/16" 1'-0"

SHEET NOTES (THIS SHEET ONLY):

1. NEW 40 TON CHILLER CONTROL ENCLOSURE.
2. NEW 100 TON CHILLER CONTROL ENCLOSURE.
3. 1" RGS WITH 8 - CAT 6 ETHERNET.
4. 1" RGS WITH 16 - #14 & #14 GND.
5. 1" RGS WITH 12 - 2/C SHIELDED #18.
6. COOLING WATER PUMP P-08-20-02 VFD.
7. COOLING WATER PUMP P-08-20-01 VFD.
8. EXISTING PLANT CONTROL ENCLOSURE.
9. NOT USED.
10. NOT USED.
11. EXISTING 3/4" RGS WITH 8 - #14, CONDENSER CONTROL ALARM.
12. NEW OUTDOOR CONDENSER.
13. 1" RGS W/ 2-2/C SHIELDED #18 COLD WATER FLOW (A) SPARE.
14. 1" RGS W/ 4 - #14 Ø 14 GNS COLD WATER
OPEN (DO)
CLOSE (DC)
OPEN (DI)
CLOSE (DI)



City of Ann Arbor
WTP Ozone Generation Building Chiller Replacement
Pre-Bid Conference Attendance
Monday, September 17, 2018 at 2:30PM

Name/Representing	Address	E-mail Address	Phone/Fax	
Eric Hinz Commerce Controls	41069 Vincanti Ct Novi, MI. 48375	ehinz@commercecontrols.com	p	734 751 2593
			f	248 474 6122
ERIC MAROWSKY JCI	1935 S. INDUSTRIAL HWY ANN ARBOR, MI 48104	ERIC.MAROWSKY@JCI.COM	p	734-780-5430
			f	
Daniel Cervenak Shaw Electric	4177 Varsity Drive A2 MI 48108	dcervenak@shawelectric.com	p	248-228-2000
			f	
Steve Katopodis Boone Darr Mech.		vicky@boone-darr.com	p	734-665-0048
			f	
Tim Gross John Darr Mechanical	293 Dino Drive Ann Arbor MI 48103	tingross@johndarrmechanical.com	p	(734) 368-1189
			f	
Jason Loucks Huron Valley Electric	425 Jackson Plaza Ann Arbor, MI 48103	jloucks@huronvalleyelectric.com	p	734 548-4733
			f	
Bill Perri Fontanesi & Kawa Co.	10777 Northend Ave FERNDALE Mich 48220	Bill.perri@ezhvac.com	p	248-240-7877
			f	



City of Ann Arbor
WTP Ozone Generation Building Chiller Replacement
Pre-Bid Conference Attendance
Monday, September 17, 2018 at 2:30PM

Name/Representing	Address	E-mail Address	Phone/Fax	
RICHARD GOYETTE GOYETTE MECHANICAL	3842 GORREY AVE FLINT, MI 48506	RGOYETTE@GOYETTE MECHANICAL.COM	p	810-523-8367
David Best D.F. BEST Co. (electrical)	628 Pathway Dr. Howell, MI 48843	dlfbest@dfbestco.com	p	517-548-0612
Bud Reedy Tech Mechanical	1490 E Highwood Pontiac 48340	bradr@techmechanical.com	p	248 514 1936
Eric W. Johnson Dunbar Mechanical	2806 W. Reynolds Ed. Toled, OH 43615	erjohnson@dunbarmechanical.com	p	
Don Boswell John E Green	2453 S. Industrial Ann Arbor, MI 48108	donboswell@john green.com	f	419.392-3047
Mike BINDER Eric Welding & Mech.	9776 S. Dixie Hwy Erie, Mi. 48133	eriewelding@Frontier. COM	p	734-848-8341
Tad Martin PTSI	734 S. Michigan Ave Howell, MI 48843	Tade@ProfessionalThermal COM	f	734-848-2109
			p	248 388 2008
			f	



**City of Ann Arbor
WTP Ozone Generation Building Chiller Replacement
Pre-Bid Conference Attendance
Monday, September 17, 2018 at 2:30PM**

Name/Representing	Address	E-mail Address	Phone/Fax	
			p	
			f	
			p	
			f	
			p	
			f	
			p	
			f	
			p	
			f	
			p	
			f	
			p	
			f	