

Addendum 1
IFB # AAHC 25-1
Lurie Terrace
Elevator Modernization

Question 1 Can car sling be retained if safeties can be replaced without removing them?

Answer Yes, the car sling can be retained only if the safeties can be replaced with type B safeties and maintain compliance.

Question 2 Is the cab enclosure (shell) to be retained with the cab interior finishes to be replaced?

Answer Yes, the cab shell is to be retained with the cab interior finishes upgraded.

Question 3 Are the car doors to be replaced and, if yes, what is the finish?

Answer Yes, the car and hoistway panels are to be replaced. The finish is no. 4 brushed stainless steel on all.

Question 4 Are the car sills to be replaced?

Answer Yes, the car sills are to be replaced with a nickel silver type.