

ADDENDUM No. 1

RFP No. 26-06

Tertiary Filter #4 – Sand Removal

Due: January 20, 2026, at 11:00 A.M. (local time)

The information contained herein shall take precedence over the original documents and all previous addenda (if any) and is appended thereto. **This Addendum includes three (3) pages.**

The Proposer is to acknowledge receipt of this Addendum No. 1 by signing and submitting Attachment B, including all attachments in its Proposal by so indicating in the proposal that the addendum has been received. Proposals submitted without acknowledgement of receipt of this addendum may be considered non-conforming.

The following forms provided within the RFP Document should be included in submitted proposal:

- **Attachment B - General Declarations**
- **Attachment C – Legal Status of Bidder?**
- **Attachment D - Prevailing Wage Declaration of Compliance**
- **Attachment E - Living Wage Declaration of Compliance**
- **Attachment G - Vendor Conflict of Interest Disclosure Form**
- **Attachment H - Non-Discrimination Declaration of Compliance**

Proposals that fail to provide these completed forms listed above upon proposal opening may be rejected as non-responsive and may not be considered for award.

I. QUESTIONS AND ANSWERS

The following Questions have been received by the City. Responses are being provided in accordance with the terms of the RFP. Respondents are directed to review the following questions and City responses to determine any impact to the proposed work or details in other areas not specifically referenced here.

Question 1: How have you previously installed sand back into the filter containment area?

Answer 1: We have not installed sand in the filter containment area in the last 25 years.

Question 2: Once the sand has been initially dewatered and we have placed the sand in the storage containers, regardless of the container used, does it matter if there is any additional leach that may occur onto the property once everything is in the container? In other words, would we need to provide additional containment around our containers to ensure the leach doesn't run onto the property road or into the soil?

Answer 2: No. The contractor would have to ensure that the runoff would not result in a nuisance such as ice or excessive soil erosion.

Question 3: Regardless of the containment used (but particularly with dumpsters), would we need to provide some sort of cover over the top of the containers to protect against the elements (rain, wind, etc)?

Answer 3: Yes.

Question 4: Is there an area allotted to store the sand?

Answer 4: Yes. We have multiple areas set aside to store the sand.

Question 5: Are there any recommended methods on how to reinstall the sand?

Answer 5: No.

Question 6: Are there structures that are below the sand that could be damaged?

Answer 6: Yes. Please refer to Appendix A for the shop drawings the diffusers and drains below the sand.

Question 7: Can we get a copy of the pre-proposal sign-in sheet?

Answer 7: Yes, see attached.

Offerors are responsible for any conclusions that they may draw from the information contained in the Addendum.

RFP26-06 - TERTIARY FILTER #4 - SAND REMOVAL
PRE-PROPOSAL MEETING
Tuesday, January 6, 2026

SIGN-IN SHEET

Name	Representing	Address	E-mail	Phone No.
Anne Warrow, Senior Engineer	City of Ann Arbor - WRRF	49 Old Dixboro Road, Ann Arbor, MI 48105	awarrow@a2gov.org	(734) 794-6410, x 43823
Keith Sanders, WRRF Manager	City of Ann Arbor - WRRF	49 Old Dixboro Road, Ann Arbor, MI 48105	ksanders@a2gov.org	(734) 794-6410, x 43822
Nick Jaworski, WRRF Assistant Manager	City of Ann Arbor - WRRF	49 Old Dixboro Road, Ann Arbor, MI 48105	njaworski@a2gov.org	(734) 794-6410, x 43821
Dave Balogh	Taplin Group, LLC	5140 West Michigan Avenue, Kalamazoo, MI 49006	davebalogh@taplinholdings.com	(269) 375-9595
Dennis Buchholz	MIS Corporation	3515 Jones Avenue, Saginaw, MI 48601	dennis@misenv.com	(517) 551-4961
Vince Catapano	MIS Corporation	3516 Jones Avenue, Saginaw, MI 48601	vince@misenv.com	(313) 477-1913