


23-A GRAVEL  
TO MATCH EXISTING  
THICKNESS (MIN. 8"),  
COMPACTED TO 98%  
MAXIMUM DENSITY.

CLASS II GRANULAR  
MATERIAL COMPACTED  
TO 95% MAXIMUM DENSITY  
PER CITY OF ANN ARBOR  
STANDARDS  
(SEE DIVISION IV REGARDING  
BACKFILL FOR PVC SEWERS)

MINIMUM TRENCH  
WIDTH PER  
CITY OF ANN ARBOR  
STANDARDS.

MINIMUM PIPE BEDDING PER  
CITY OF ANN ARBOR  
SPECIFICATIONS (4" MIN.)

- NOTE: DENSITY TESTING PER CITY ANN ARBOR SPECIFICATION
- NOTE: TRENCH DETAILS SHOW TYPE OF BACKFILL AND SURFACE RESTORATION ONLY.
- NOTE: ALL TRENCHING TO CONFORM TO ALL APPLICABLE M.I.O.S.H.A. STANDARDS

REVISIONS		REV. NO.	DR. BY	CH. BY	DATE
<b>PUBLIC SERVICES DEPARTMENT</b>					
<b>CITY OF ANN ARBOR</b>					
UTILITY TRENCH—TYPE II (UNDER GRAVEL ROAD)					
DR. BY	DF	CH. BY	CSS	DRAWING NO.	
SCALE	NONE	DATE	11-6-92	SD-TD-2	
INCH	0  1			SHEET NO. ____ OF ____	