

ADDENDUM No. 1

ITB No. 4513

VETERANS MEMORIAL PARK POOL LINER REPLACEMENT

Due: Thursday, September 21, 2017 at 2:00 P.M. (local time)

The following changes, additions, and/or deletions shall be made to the Invitation to Bid for Pool Liner Replacement at Veterans Memorial Park, ITB No. 4513, on which proposals will be received on/or before Thursday, September 21, 2017 at 2:00 P.M.

The information contained herein shall take precedence over the original documents and all previous addenda (if any), and is appended thereto. **This Addendum includes 1 page.**

Bidder is to acknowledge receipt of this Addendum No. 1, including all attachments in its Bid by so indicating on page ITB-1 of the Invitation to Bid Form. Bids submitted without acknowledgement of receipt of this addendum may be considered nonconforming.

The following forms provided within the ITB Document must be included in submitted bids at bid opening.

- **City of Ann Arbor Prevailing Wage Declaration of Compliance**
- **City of Ann Arbor Living Wage Ordinance Declaration of Compliance**
- **Vendor Conflict of Interest Disclosure Form**
- **City of Ann Arbor Non-Discrimination Ordinance Declaration of Compliance**

Bids that fail to provide these completed forms listed above upon bid opening will be rejected as non-responsive and will not be considered for award.

I. QUESTIONS AND ANSWERS

The following Questions have been received by the City. Responses are being provided in accordance with the terms of the ITB. Respondents are directed to take note in its review of the documents of the following questions and City responses as they affect work or details in other areas not specifically referenced here.

Question 1: Can a bidder just bid on one option? We don't offer options B or C. We just offer the PVC liner.

Answer 1: Within the ITB Document for ITB# 4513, see Page BF-1, #1 where it states the following: Bidders are encouraged to but not required to submit bids for all three (3) of the proposed pool liner system options (Bid Options A thru C).

Question 2: Does the PVC membrane option require a stainless steel skirt be welded to the bottom of the existing gutter?

Answer 2: Yes, the PVC option requires a stainless steel skirt be welded to the bottom of the existing gutter.

Respondents are responsible for any conclusions that they may draw from the information contained in the Addendum.