

ADDENDUM No. 2

RFP No. 24-10

2024 Miscellaneous Utilities Project

Due Date: March 5, 2024, by 11:00 a.m. (local time)

The information contained herein shall take precedence over the original documents and all previous addenda (if any) and is appended thereto. **This Addendum includes a total of 2 pages.**

The Proposer is to acknowledge **receipt of this Addendum No. 2 by signing and submitting attachment B**, including all attachments in its Proposal by so indicating in the proposal that the addendum has been received. Proposals submitted without acknowledgement of receipt of this addendum may be considered non-conforming.

The following forms provided within the RFP Document should be included in submitted proposal:

- **Attachment D - Prevailing Wage Declaration of Compliance**
- **Attachment E - Living Wage Declaration of Compliance**
- **Attachment G - Vendor Conflict of Interest Disclosure Form**
- **Attachment H - Non-Discrimination Declaration of Compliance**

Proposals that fail to provide these completed forms listed above upon proposal opening may be rejected as non-responsive and may not be considered for award.

I. CORRECTIONS/ADDITIONS/DELETIONS

Changes to the RFP documents which are outlined below are referenced to a page or Section in which they appear conspicuously. Offerors are to take note in their review of the documents and include these changes as they may affect work or details in other areas not specifically referenced here.

| Section/Page(s) | Change |
|-----------------|--------|
|-----------------|--------|

| | |
|----------------------|--|
| <u>Clarification</u> | |
|----------------------|--|

| | |
|---------------------|--|
| Sheet 21 – 24 of 46 | |
|---------------------|--|

| | |
|-----------------------------|--|
| Huronview Water Main Sheets | |
|-----------------------------|--|

| |
|--|
| All 20-inch water main pipe and fitting joints shall be restrained, per Section II.A.3.a of Article 3 of the 2024 Ann Arbor Public Services Standard Specifications. |
|--|

| |
|---|
| The Huronview profile calls out specific lengths of pipe to be restrained. This addendum is to clarify that these labels are redundant. The contractor shall restrain all joints on water main pipe and fittings greater than 12-inches in diameter. |
|---|

Water Main Pipe Material

Per Section II.A.1. and 2. of Article 3 of the 2024 Ann Arbor Public Services Standard Specifications, pipe shall be:

Pressure Class (PC) 350 with standard thickness cement-mortar lining for 12-inch and smaller and
PC 250 with standard thickness cement-mortar lining for 14-20-inch.

No Thickness Class is specified. Thickness Class 50 or above exceed the requirements and will be accepted.

Offerors are responsible for any conclusions that they may draw from the information contained in the Addendum.