

ADDENDUM No. 1

RFP No. 983

Streetlight Condition Assessment

Due: October 27, 2016 at 2:00 P.M.

The following changes, additions, and/or deletions shall be made to the Request for Proposal for Streetlight Condition Assessment, RFP No. 983, on which proposals will be received on/or before October 27, 2016, by 2:00 P.M.

The information contained herein shall take precedence over the original documents and all previous addenda (if any), and is appended thereto. **This Addendum includes 4 page(s) not including attachments.**

Respondent is to acknowledge receipt of this Addendum No. 1, including all attachments (if any) in its proposal by so indicating on in the proposal that the addendum has been received. Proposals submitted without acknowledgement of receipt of this addendum will be considered nonconforming.

The following forms provided within the RFP Document must be included in the submitted proposal:

- City of Ann Arbor Non-Discrimination Ordinance Declaration of Compliance
- City of Ann Arbor Living Wage Ordinance Declaration of Compliance
- Vendor Conflict of Interest Disclosure Form

Proposals that fail to provide these completed forms listed above upon proposal opening may be deemed non-responsive and may not be considered for award.

I. QUESTIONS AND ANSWERS

The following Questions have been received by the City. Responses are being provided in accordance with the terms of the RFP.

Question 1 What is the anticipated schedule for this project?

Answer 1 This project is anticipated to begin in January, 2017 and the City would like all condition assessment data back by June 30, 2017. The consultant shall provide a preliminary deliverable by April 2017 with the condition assessment information for the approximately 770 streetlights within the Downtown Development Authority boundary.

Question 2 Does the proposal have a page limit?

Answer 2 Yes, proposals should not be more than 15 sheets (30 sides), not including required attachments and resumes.

- Question 3** What are the City's expectations for deliverables?
- Answer 3** The following is the minimum deliverable list the City is requesting:
- Memo indicating data gaps within the current streetlight inventory.
 - An updated streetlight GIS geodatabase with all new data and condition information incorporated.
 - Estimated remaining life information for all streetlights/or groupings of similar streetlights and associated documentation detailing remaining life calculations.
 - Streetlight replacement prioritization information for all streetlights/or groups of similar streetlights and documentation on the methodology for prioritizing the replacement.
- Question 4** Does the City want confirmed GPS location data at each location as part of the verification audit? If so, is there a required level of accuracy for this data (e.g. +/- 1 meter)?
- Answer 4** The existing location data within the City's GIS database for the streetlights is acceptable and new GPS location data is not required. If streetlights are found in a different location, or additional streetlights are found, they should be brought to the City's attention.
- Question 5** Please confirm that all of the required data to be collected is to be collected without touching any street lighting components?
- Answer 5** The City has prepared a draft information list to obtain within the proposal, and the respondent shall clarify the information they will obtain and how they intend to obtain that information. The City would like to cost effectively gather as much relevant condition information through this project, some of which may require touching the streetlight. It is the responsibility of the respondent to utilize competent staff to safely inspect lighting components.
- Question 6** For the Fee Proposal, would the City be open to a per fixture price for each Task (as opposed to an hourly rate and estimated hours by Task)?
- Answer 6** The City is open to a per fixture price for each task. The respondent must still provide a breakdown of the staff, equipment and hours utilized to develop the pricing.
- Question 7** Do you currently use an asset management program associated with a GIS system?
- Answer 7** The City currently utilizes Cityworks only to track outside requests for streetlight repairs.
- Question 8** While inspecting the foundation, does the City want information on the size, shape, material, and condition?
- Answer 8** Yes, if visible.
- Question 9** When referring to base plate, are you referring to a transformer base or the base plate of the pole attached to the bolts?
- Answer 9** This refers to the base plate of the pole and the associated bolts.

- Question 10** When inspecting pole base and anchor bolts, removing the shroud and caps will be required. Do you have a supply of replacements if needed?
- Answer 10** The consultant will only be required to inspect these elements if they are readily accessible. For example, if the bolts are visible after opening the access panel, then they should be assessed. However, if the panel cannot be removed or the bolts are under the shroud, then they will not be inspected.
- Question 11** Will you require a test burn of each light to determine operation?
- Answer 11** No
- Question 12** Will you be supplying the vendor with circuit maps with controller locations identified?
- Answer 12** No
- Question 13** Will you require wire gauge identification and conductor material?
- Answer 13** No
- Question 14** Will you require photo documentation for each component of the assessment?
- Answer 14** At a minimum the consultant shall provide an overall picture of each streetlight and a close-up picture of the base/foundation. The files should be named so they can easily be linked back to the streetlight ID.
- Question 15** Do you have data and specification sheets from each manufacturer of your current luminaires?
- Answer 15** The current database has luminaire manufacturer and model information for 70% of the streetlights. Specification sheets are not available from the City for all models.
- Question 16** Do you have data and specification sheets from each manufacturer of your current lamp posts?
- Answer 16** The current database does **not** have information on the manufacturer and model of the lamp posts. The database does contain general pole type information for 90% of the lamp posts (e.g. aluminum, steel, fiberglass, etc.)
- Question 17** How many manhole / hand holes are to be inspected? Will any require traffic plans, permits, and entry approval from the City or other utility?
- Answer 17** None, City staff will handle condition assessment of any underground infrastructure. Data gaps associated with the underground infrastructure shall be identified by the Consultant.
- Question 18** Do you have any existing condition assessment data currently? If so, can you share an example?
- Answer 18** Yes, the City gathered condition assessment information for 138 streetlights in January, 2016. A spreadsheet identifying the gathered information is attached for reference.

Question 19 What percentage of luminaires will require a physical inspection from an aerial lift / bucket truck?

Answer 19 The consultant should develop a plan which cost effectively gathers enough condition information to plan for streetlight replacement needs. It is assumed that only a small percentage of poles will receive a physical inspection with an aerial lift and the remaining condition information will be gathered from the ground.

Respondents are responsible for any conclusions that they may draw from the information contained in the Addendum.

Light Pole Inspections

Coding
 1 Acceptable Condition
 2 Poor Condition
 3 Bad Condition
 U Unable to Open Door/Unable to Inspect
 M Part Missing

Light Pole #	Location	Date Inspected	Luminaires	# of Lights	Cast Exterior Pipe	Inner Galv. Pipe	Base	Door	Base Plate	Anchor Bolts	Wiring	Fuses	Terminations	Pole Stability	Hammer Test	Foundation	Foundation Shape	Foundation Size	Grade	Notes
Kerrytown, 72 Light Poles																			11.0	
25-04792	NE Cor Catherine & Fourth	1/27/2016	1	1	1	1	2	3	1	1	1	1	1	3	2	1	Square	16 x 16	14	Base Starting to Rust
25-04794	SE Cor Kingsley & Fourth	1/27/2016	1	1	1	U	2	U	U	U	U	U	U	3	2	3	Square	16 x 16	23	Door won't open / Base Starting to Rust
25-04796	SE Cor Kingsley & Fourth	1/27/2016	1	1	1	1	3	2	1	1	3	1	3	2	3	1	Square	16 x 16	21	Broken Base
25-04798	SE Cor Kingsley & Fourth	1/27/2016	1	1	1	1	1	3	1	1	2	1	2	2	1	1	Square	16 x 16	10	Broken Door
25-04802	SE Cor Kingsley & Fourth	1/27/2016	1	1	1	1	3	3	1	1	2	1	2	2	3	1	Square	16 x 16	18	
25-00099	SE Cor Kingsley & Fourth	1/27/2016	1	2	1	1	3	3	1	1	1	1	1	3	3	1	Square	16 x 16	18	Broken Base
25-00094	SW Cor Kingsley & Fourth	1/27/2016	1	2	1	1	2	M	1	1	1	3	1	2	2	1	Square	16 x 16	12.5	Missing Door, Rust at Base
25-04803	SW Cor Kingsley & Fourth	1/27/2016	1	1	1	U	2	U	U	U	U	U	U	3	2	1	Square	16 x 16	19	Door screws stripped
25-04801	SW Cor Kingsley & Fourth	1/27/2016	1	1	1	U	2	U	U	U	U	U	U	2	2	1	Square	16 x 16	15	Door screws stripped
25-04800	SW Cor Kingsley & Fourth	1/27/2016	1	1	1	1	1	2	1	1	1	1	1	3	1	1	Square	16 x 16	9	
25-04797	SW Cor Kingsley & Fourth	1/27/2016	1	1	1	1	1	2	1	1	2	1	2	2	1	1	Square	16 x 16	9	
25-04795	SW Cor Kingsley & Fourth	1/27/2016	1	1	1	U	2	U	U	U	U	U	U	2	2	1	Square	16 x 16	15	Door screws stripped
25-04793	SW Cor Kingsley & Fourth	1/27/2016	1	1	1	1	1	1	1	1	3	1	2	2	1	1	Square	16 x 16	10	
25-00097	NE Cor Catherine & Fourth	1/27/2016	1	2	1	1	2	2	1	1	3	1	2	2	2	1	Square	16 x 16	15	
25-04777	NE Cor Catherine & Fourth	1/27/2016	1	1	1	1	2	2	1	1	2	1	1	2	2	1	Square	16 x 16	11	
25-04786	NE Cor Catherine & Fourth	1/27/2016	1	1	1	1	2	2	1	1	2	1	2	2	2	1	Square	16 x 16	13	
25-04788	NE Cor Catherine & Fourth	1/27/2016	1	1	1	1	1	2	1	1	1	1	1	2	1	1	Square	16 x 16	5	
25-04790	NE Cor Catherine & Fourth	1/27/2016	1	1	1	1	3	3	1	1	2	3	2	2	3	1	Square	16 x 16	22	
25-04791	NE Cor Braun Ct & Fourth	1/27/2016	1	1	1	U	1	U	U	U	U	U	U	1	1	1	Square	16 x 16	7	Door screws stripped
25-04789	SE Cor Braun Ct & Fourth	1/27/2016	1	1	1	U	2	U	U	U	U	U	U	1	2	1	Square	16 x 16	11	Door screws stripped
25-04787	NW Cor Catherine & Fourth	1/27/2016	1	1	1	1	1	3	1	1	2	1	2	1	1	1	Square	16 x 16	6	
25-04785	NW Cor Catherine & Fourth	1/27/2016	1	1	1	U	2	U	U	U	U	U	U	2	2	1	Square	16 x 16	15	Door screws stripped
25-00091	NW Cor Catherine & Fourth	1/27/2016	1	2	1	U	3	U	U	U	U	U	U	1	3	1	Square	16 x 16	15	Door screws stripped
25-03641	SW Cor Catherine & Fourth	1/27/2016	1	1	1	1	2	2	1	3	2	1	2	1	2	1	Square	16 x 16	17	
25-04992	SW Cor Catherine & Fourth	1/27/2016	1	1	1	U	2	U	U	U	U	U	U	1	2	3	Square	16 x 16	15	Door screws stripped
25-00090	SW Cor Catherine & Fourth	1/27/2016	1	2	1	U	2	U	U	U	U	U	U	1	2	1	Square	16 x 16	11	Door screws stripped
25-011079	SE Cor Catherine & Fourth	1/27/2016	1	2	1	1	2	2	1	1	1	M	1	2	2	1	Round	16	10	
25-04993	SE Cor Catherine & Fourth	1/27/2016	1	5	1	1	1	1	1	1	1	M	1	2	1	1	Round	16	5	
25-03640	SE Cor Catherine & Fourth	1/27/2016	1	1	1	1	2	1	1	1	1	M	1	2	1	1	Square	16 x 16	7	
25-03638	SE Cor Catherine & Fourth	1/27/2016	1	1	1	1	1	3	1	1	1	M	1	2	1	U		8	Foundation under sidewalk	
25-03636	NE Cor Ann & Fourth	1/27/2016	1	1	1	U	2	U	U	U	U	U	U	2	2	2	Square	16 x 16	17	Door screws stripped
25-00096	NE Cor Ann & Fourth	1/27/2016	1	2	1	1	2	2	1	1	1	M	1	1	2	3	Square	16 x 16	10	
25-04042	NE Cor Ann & Fourth	1/27/2016	1	2	1	1	1	1	1	1	1	1	1	2	1	1	Round	16	4	
25-04041	NE Cor Ann & Fourth	1/27/2016	1	1	1	1	1	1	1	1	1	1	1	2	1	1	Round	16	4	
25-03639	NW Cor Ann & Fourth	1/27/2016	1	1	1	1	1	1	1	1	2	1	2	3	1	1	Square	16 x 16	12	
25-03637	NW Cor Ann & Fourth	1/27/2016	1	1	1	1	1	2	1	1	3	1	3	3	1	1	Square	16 x 16	17	
25-00082	NW Cor Ann & Fourth	1/27/2016	1	2	1	U	1	U	U	U	U	U	U	2	1	1	Square	16 x 16	11	Door screws stripped
25-04043	NW Cor Ann & Fourth	1/27/2016	1	2	1	U	2	U	U	U	U	U	U	2	2	1	Square	16 x 16	15	Door screws stripped
None	NW Cor Ann & Fourth	1/27/2016	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Round	16	0	
25-04044	NW Cor Ann & Fourth	1/27/2016	1	1	1	1	1	1	1	1	1	1	1	2	1	1	Round	16	4	
25-04045	NE Cor Ann & Main	1/27/2016	1	1	1	1	1	1	1	1	1	1	1	2	1	1	Round	16	4	
None	SE Cor Ann & Main	1/26/2016	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Round	16	0	
25-04046	SW Cor Ann & Fourth	1/26/2016	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Round	16	0	
25-04047	SW Cor Ann & Fourth	1/26/2016	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Round	16	0	
25-04036	SW Cor Ann & Fourth	1/26/2016	1	2	1	1	1	1	1	1	1	1	1	2	1	1	Round	16	4	
25-04035	SW Cor Ann & Fourth	1/26/2016	1	2	1	1	1	3	1	1	1	M	1	1	1	1	Round	16	3	
25-04034	SW Cor Ann & Fourth	1/26/2016	1	1	1	U	1	U	U	U	U	U	U	2	1	1	Round	16	11	Door screws stripped
25-04033	SW Cor Ann & Fourth	1/26/2016	1	1	2	1	1	3	1	1	1	M	1	2	1	1	Round	16	10	
25-02727	NW Cor Huron & Fourth	1/26/2016	1	1	1	1	1	3	1	1	1	M	1	2	1	3	Round	16	11	
25-02437	NW Cor Huron & Fourth	1/26/2016	1	1	1	1	1	3	1	1	1	M	1	2	1	1	Round	16	7	
25-00726	NW Cor Huron & Fourth	1/26/2016	1	2	1	1	1	1	1	1	1	1	1	2	1	2	Round	16	6	
25-04040	SW Cor Ann & Fifth	1/26/2016	1	2	1	U	2	U	U	U	U	U	U	2	2	1	Round	16	15	Door screws stripped

Light Pole #	Location	Date Inspected	Luminaires	# of Lights	Cast Exterior Pipe	Inner Galv. Pipe	Base		Base Plate	Anchor Bolts	Wiring	Fuses	Terminations	Pole Stability	Hammer		Foundation		Foundation Size	Foundation Grade	Notes
							Base	Door							Test	Foundation	Shape				
25-07111	SE Cor Ann & Fourth	1/26/2016	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Round	16	0	
25-03635	SE Cor Ann & Fourth	1/26/2016	1	2	1	U	2	U	U	U	U	U	U	2	2	3	Square	16 x 16	19	Door screws stripped	
25-03634	SE Cor Ann & Fourth	1/26/2016	1	1	1	U	2	U	U	U	U	U	U	2	2	2	Square	16 x 16	17	Door screws stripped	
25-03633	SE Cor Ann & Fourth	1/26/2016	1	1	1	U	1	U	U	U	U	U	U	2	1	2	Square	16 x 16	13	Door screws stripped	
25-03632	NE Cor Huron & Fourth	1/26/2016	1	1	1	U	2	U	U	U	U	U	U	1	2	2	Square	16 x 16	13	Door screws stripped	
25-03631	NE Cor Huron & Fourth	1/26/2016	1	1	1	U	2	U	U	U	U	U	U	1	2	2	Square	16 x 16	13	Door screws stripped	
25-00095	NE Cor Huron & Fourth	1/26/2016	1	2	1	U	2	U	U	U	U	U	U	2	2	2	Square	16 x 16	17	Door screws stripped	
25-00106	NW Cor Catherine & Fifth	1/28/2016	1	2	1	1	1	2	1	1	1	M	1	2	1	1	Round	16	6		
25-05281	NW Cor Catherine & Fifth	1/28/2016	1	1	1	1	1	1	1	1	1	1	1	2	1	1	Round	16	4		
25-05282	NW Cor Catherine & Fifth	1/28/2016	3	1	1	1	1	1	1	1	M	1	2	1	1	Round	16	7			
25-00101	NE Cor Catherine & Fourth	1/28/2016	1	5	1	3	3	3	3	3	2	1	2	3	3	3	Square	16 x 16	46		
25-05316	NE Cor Catherine & Fourth	1/28/2016	1	2	1	1	1	1	1	1	1	1	1	2	1	1	Square	16 x 16	4		
25-00102	Catherine & Detroit	1/28/2016	1	2	1	1	1	1	1	1	1	1	1	2	1	1	Round	16	4		
25-05295	SW Cor Kingsley & Detroit	1/28/2016	1	1	1	1	1	1	1	2	1	M	1	2	1	2	Round	16	11		
25-00117	SW Cor Kingsley & Detroit	1/28/2016	1	2	1	U	2	U	U	U	U	U	U	2	2	2	Round	16	17	Door screws stripped	
25-00107	SW Cor Kingsley & Fifth	1/28/2016	1	2	1	1	2	2	1	1	3	1	2	2	2	1	Round	16	15		
25-05294	SW Cor Kingsley & Fifth	1/28/2016	1	1	1	1	2	1	1	1	1	1	2	1	2	1	Round	16	6		
25-05293	SE Cor Kingsley & Fourth	1/28/2016	1	1	1	1	2	2	1	1	1	M	2	2	2	1	Round	16	12		
25-05292	SE Cor Kingsley & Fourth	1/28/2016	1	1	1	1	1	2	1	1	2	1	1	2	1	1	Round	16	7		
25-00100	SE Cor Kingsley & Fourth	1/28/2016	1	2	1	1	3	2	1	1	1	1	2	1	3	1	Square	16 x 16	11		

Fifth - Catherine to Kingsley, 12 Light Poles

11.1

25-05284	NE Cor Catherine & Fifth	1/28/2016	1	1	1	1	2	1	1	2	1	1	1	2	2	2	Round	16	14	
25-07122	NE Cor Catherine & Fifth	1/28/2016	1	1	1	1	1	1	1	1	2	1	3	2	1	2	Round	16	12	
25-00113	NE Cor Catherine & Fifth	1/28/2016	1	2	1	1	1	1	1	1	1	1	1	2	1	1	Round	16	4	
25-05285	Detroit & Fifth	1/28/2016	1	1	1	1	1	2	1	1	1	1	1	2	1	1	Round	16	5	
25-05286	SE Cor Detroit & Fifth	1/28/2016	1	1	1	1	1	1	1	1	1	1	1	2	1	2	Round	16	6	
25-05287	SE Cor Detroit & Fifth	1/28/2016	1	1	1	1	1	1	1	1	M	1	2	1	2	Round	16	7		
25-00109	NW Cor Detroit & Fifth	1/28/2016	1	5	1	U	2	U	U	U	U	U	U	1	2	2	Round	16	13	Door screws stripped
25-05445	NW Cor Detroit & Fifth	1/28/2016	1	5	2	3	3	3	3	3	2	1	2	1	3	2	Square	16 x 16	39	
25-05296	SW Cor Kingsley & Fifth	1/28/2016	1	1	1	1	2	2	1	1	1	M	1	2	2	1	Square	16 x 16	10	
25-00110	SW Cor Kingsley & Fifth	1/28/2016	1	2	1	1	2	2	1	1	1	1	2	3	2	1	Round	16	15	
25-05283	NW Cor Catherine & Fifth	1/28/2016	1	1	1	1	1	1	1	1	1	1	1	2	1	1	Round	16	4	
25-00108	NW Cor Catherine & Fifth	1/28/2016	1	2	1	1	1	1	1	1	1	1	1	2	1	1	Round	16	4	

Detroit Street - Catherine to Kingsley, 11 Light Poles

9.6

25-03327	Catherine & Detroit	1/28/2016	1	1	1	1	1	1	1	1	1	1	1	2	1	1	Round	16	4	
25-03328	Catherine & Detroit	1/28/2016	1	1	1	1	1	2	1	1	1	1	1	2	1	1	Round	16	5	
25-03329	Detroit & Fifth	1/28/2016	1	1	1	1	2	2	1	1	1	1	1	2	2	1	Round	16	9	
25-03330	Detroit & Fifth	1/28/2016	1	1	1	1	1	2	1	1	1	1	1	2	1	1	Round	16	5	
25-00120	SE Cor Kingsley & Detroit	1/28/2016	1	2	2	U	3	U	U	U	U	U	U	3	3	2	Round	16	28	Door screws stripped
25-05288	SE Cor Kingsley & Detroit	1/28/2016	1	1	1	U	2	U	U	U	U	U	U	2	2	1	Round	16	15	Door screws stripped
25-00480	SE Cor Kingsley & Detroit	1/28/2016	1	1	1	1	2	2	1	1	1	M	1	2	2	2	Round	16	12	
25-05290	NE Cor Detroit & Fifth	1/28/2016	1	1	1	1	2	1	1	1	1	M	1	2	2	1	Round	16	9	
25-05289	Kingsley & Detroit	1/28/2016	1	1	1	1	1	1	1	1	1	M	1	2	1	2	Round	16	7	
25-00118	SW Cor Kingsley & Detroit	1/28/2016	1	2	1	1	1	1	1	1	1	M	1	2	1	1	Round	16	5	
25-05237	NE Cor Detroit & Fifth	1/28/2016	1	1	1	1	1	1	1	1	1	M	1	2	1	2	Round	16	7	

Light Pole #	Location	Date Inspected	Luminaires	# of Lights	Cast Exterior Pipe	Inner Galv. Pipe	Base	Door	Base Plate	Anchor Bolts	Wiring	Fuses	Terminations	Pole Stability	Hammer Test	Foundation	Foundation Shape	Foundation Size	Grade	Notes
Liberty Street - First to Main, 22 Light Poles																			12.0	
25-04892	SE Cor Liberty & First	1/26/2016	1	1	1	1	2	2	1	1	2	1	2	2	2	1	Square	16 x 16	13	
25-04894	SE Cor Liberty & First	1/26/2016	1	1	1	1	2	2	1	1	2	1	2	3	2	1	Square	16 x 16	17	
25-04896	SW Cor Liberty & Ashley	1/26/2016	1	1	1	U	2	U	U	U	U	U	U	3	2	1	Square	16 x 16	19	Pole Leaning Over Badly /Door screws stripped
25-00034	SW Cor Liberty & Ashley	1/26/2016	1	1	1	U	2	U	U	U	U	U	U	1	2	1	Square	16 x 16	11	Door screws stripped
25-00035	SE Cor Liberty & Ashley	1/26/2016	1	1	1	1	2	2	1	1	3	1	3	2	2	1	Square	16 x 16	17	
25-04898	SE Cor Liberty & Ashley	1/26/2016	1	1	1	1	2	M	1	1	2	1	3	2	2	1	Square	16 x 16	14.5	
25-04900	SE Cor Liberty & Ashley	1/26/2016	1	1	1	1	2	2	1	1	2	1	2	1	2	1	Square	16 x 16	9	
25-04901	NE Cor Liberty & Ashley	1/26/2016	1	1	1	U	1	U	U	U	U	U	U	2	1	1	Square	16 x 16	11	Door screws stripped
25-04899	NE Cor Liberty & Ashley	1/26/2016	1	1	1	1	2	3	1	1	3	1	3	2	2	1	Square	16 x 16	18	
25-00036	NE Cor Liberty & Ashley	1/26/2016	1	1	1	1	2	3	1	1	2	1	2	3	2	1	Square	16 x 16	18	
25-00033	NW Cor Liberty & Ashley	1/26/2016	1	1	1	1	1	3	1	1	2	1	2	2	1	1	Square	16 x 16	10	
25-04897	NW Cor Liberty & Ashley	1/26/2016	1	1	1	1	2	3	1	1	2	1	2	2	2	1	Square	16 x 16	14	
25-04895	NW Cor Liberty & Ashley	1/26/2016	1	1	1	U	1	U	U	U	U	U	U	2	1	1	Square	16 x 16	11	Door screws stripped
25-04893	NE Cor Liberty & First	1/26/2016	1	1	1	U	3	U	U	U	U	U	U	2	3	1	Square	16 x 16	19	Door screws stripped
25-04891	NE Cor Liberty & First	1/26/2016	1	1	1	U	2	U	U	U	U	U	U	2	2	1	Square	16 x 16	15	Door screws stripped
25-00029	NE Cor Liberty & First	1/26/2016	1	5	1	1	2	3	1	1	2	1	2	2	2	1	Square	16 x 16	14	
25-00041	SW Cor Liberty & Main	1/25/2016	1	2	1	1	3	1	1	1	2	U	U	1	2	1	Square	16 x 16	8.5	
25-00038	NW Cor Liberty & Main	1/25/2016	1	1	1	1	1	3	1	1	1	1	1	1	1	1	Square	16 x 16	2	
25-04904	NW Cor Liberty & Main	1/25/2016	1	1	1	U	1	U	U	U	U	U	U	2	1	1	Square	16 x 16	11	Door screws stripped
25-00042	NW Cor Liberty & Main	1/25/2016	1	2	1	1	1	2	1	1	1	1	1	2	1	1	Square	16 x 16	5	
25-04903	SW Cor Liberty & Main	1/25/2016	1	1	1	1	1	U	U	U	U	U	U	1	1	1	Square	16 x 16	5.5	Door screws stripped
25-04902	SW Cor Liberty & Main	1/25/2016	1	1	1	1	1	M	1	1	1	1	1	1	1	1	Square	16 x 16	0.5	

Liberty Street - Main to Fifth, 21 Light Poles																			7.0	
25-00069	SE Cor Liberty & Main	1/25/2016	1	2	1	1	1	3	1	1	1	1	1	1	1	2	Square	16 x 16	4	
25-03604	SE Cor Liberty & Main	1/25/2016	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Square	16 x 16	0	
25-03602	SE Cor Liberty & Main	1/25/2016	1	1	3	3	1	1	1	1	1	1	1	2	1	1	Square	16 x 16	16	Top part of pole bending over
25-00093	NE Cor Liberty & Fourth	1/26/2016	1	1	1	1	1	3	1	1	1	1	1	2	1	U	Square	16 x 16	7	Foundation under sidewalk
25-03609	NE Cor Liberty & Fourth	1/26/2016	1	1	1	1	1	3	1	1	1	1	1	1	2	Square	16 x 16	4		
25-03608	NE Cor Liberty & Fourth	1/26/2016	1	1	1	1	1	3	1	1	1	1	1	2	1	1	Square	16 x 16	6	
25-03607	NE Cor Liberty & Fourth	1/26/2016	1	1	1	1	2	3	1	1	1	1	1	2	2	1	Square	16 x 16	10	
25-03606	NW Cor Liberty & Fifth	1/26/2016	1	1	1	1	1	3	1	1	1	1	1	2	1	2	Square	16 x 16	8	
25-03600	SW Cor Liberty & Fourth	1/25/2016	1	1	1	1	1	3	1	1	1	1	1	2	1	1	Square	16 x 16	6	
25-03598	SW Cor Liberty & Fourth	1/25/2016	1	1	1	1	2	2	1	1	1	1	1	1	1	1	Square	16 x 16	3	
25-00076	SW Cor Liberty & Fourth	1/25/2016	1	2	1	1	3	3	1	1	1	1	1	2	3	1	Square	16 x 16	14	
25-02593	SW Cor Liberty & Fourth	1/25/2016	1	2	1	1	1	M	1	1	1	M	1	2	1	1	Round	16	5.5	
25-00089	SE Cor Liberty & Fourth	1/25/2016	1	2	1	1	1	3	1	1	1	M	1	2	1	1	Round	16	7	
25-03601	NW Cor Liberty & Fourth	1/25/2016	1	1	1	1	1	3	1	1	1	1	1	2	1	2	Square	16 x 16	8	
25-03599	NW Cor Liberty & Fourth	1/25/2016	1	1	1	1	1	2	1	1	1	1	1	2	1	1	Square	16 x 16	5	
25-00077	NW Cor Liberty & Fourth	1/25/2016	1	2	1	1	1	M	1	1	1	1	1	2	1	2	Square	16 x 16	6.5	
25-00078	NW Cor Liberty & Fourth	1/25/2016	1	2	1	U	1	U	U	U	U	U	U	1	1	1	Square	16 x 16	7	Door screws stripped
25-03624	NE Cor Liberty & Fourth	1/25/2016	1	2	1	U	1	U	U	U	U	U	U	1	1	1	Square	16 x 16	7	Door screws stripped
25-00072	NE Cor Liberty & Main	1/25/2016	1	2	1	1	1	2	1	2	1	1	1	1	1	2	Square	16 x 16	7	
25-03605	NE Cor Liberty & Main	1/25/2016	1	1	1	1	1	3	1	1	1	1	1	2	2	1	Square	16 x 16	8	
25-03603	NE Cor Liberty & Main	1/25/2016	1	1	1	1	1	3	1	1	1	1	1	2	1	2	Square	16 x 16	8	